



SPECIFICATION

PVCu A-Rated Windows

The Rehau Total 70 system has passed the BS6375 part 1 for air permeability, water tightness and wind resistance; the BS Board of Agreement system assessment and Airo sound reduction index (38 dB)

Rehau are a BS5750 (Quality Control) registered company, who also holds the kite mark to BS7413

<p>Frame Rehau Total 70</p>	<ul style="list-style-type: none"> • 70mm Profile • Interior Glazed • Or Exterior Glazed [Re-secure security gaskets used] • Moulded glazing bead • five chambered profile [for thermal insulation] • Low line security gaskets • Welded construction • Steel Reinforced [over 1300mm] • Fixing 'Fisher' 10 x 100mm plated expanding bolts
<p>Opening Sashes</p>	<ul style="list-style-type: none"> • Adjustable stainless steel friction stays [60° security cup openings] • Two position key locking handles [Night Vent] • Stainless steel shoot bolt espagneolette mechanism [with anti jemmy buttons engaging a die cast keep] • Heavy duty weather gaskets of EDPM • Moulded glazing bead • Sashes over 800mm have locating wedge ensuring gasket is engaged • Steel reinforced [over 600mm]
<p>Glazing</p>	<ul style="list-style-type: none"> • 28mm Sealed units [4/20/4] Argon Gas filled • Planitherm outer pane, Pilkington optiwhite float or obscure glass • Toughened glass where less than 800mm from floor or adjacent to a door • Edgetech warm edge Super Spacer bar.
<p>Reinforcement</p>	<ul style="list-style-type: none"> • Galvanised steel of 30 x 10mm (or greater) used in. <p>Outer frames over 1300mm Sashes over 600mm All Mullions and Transoms</p>

All making good as necessary. Includes external trimming and mastic beading

Design is computer checked to ensure adherence to the manufacturers criteria

Fabrication by Rehau trained and certificated personnel